

Office of Sub Divisional Engineer, W/S & Sanitation Sub Division No. 1,
Sri Muktsar Sahib

No. 597

Dated: 12/08/2026

"Sanitary Conditions Certificate"

It is certified that Sacred Heart Public School, Jando Ke District Sri Muktsar Sahib has well maintained toilets and urinals. Drinking water facility is good.

The Sanitary conditions of above said school are good.

Note: This Certificate is valid for only one year 2026-27.


Sub Divisional Engineer,
W/S & Sanitation Sub Div 1,
Sri Muktsar Sahib 

DISTRICT WATER TESTING LABORATORY, SH. MUKTSAR SAHIB

Water Supply and Sanitation Department, Division no 1, kotkapoora road near vishal mega Mart ,Distt

Muktsar ,Pin code 152026

dwtlmks@gmail.com

To,

sacred heart public school
jando ke


No.: DWTL/MKS/2627/00171 Dated : 07/07/2026

Subject : Testing Reports of Water Samples.

Reference: Your Letter/SRF No. 3137 Dated: 03/07/2026

As per above cited subject and reference, Please find enclosed here with the report of 1 Water sample/s received on dated 03/07/2026. It is request to fill the attached feedback form and send it back to District Water Testing Laboratory, Sh. Muktsar Sahib

D/A : Test Report



**Authorized Signatory
For, District Water Testing Laboratory
Sh. Muktsar Sahib**

TEST REPORT

Name & Address of Customer : sacred heart public school jando ke			Customer Reference No.		No : 3137 Dated : 03/07/2026	
			Sample Submitted by		rohit kumar	
			Date of Sample Receipt		03/07/2026	
			Analysis Starting Date		03/07/2026	
			Analysis completion Date		04/07/2026	
Discipline : Chemical Testing			Group: Water			
ULR No.:			Sample Type :		Treated Water	
Test Report No.:		DWTL/MKS/2627/00171		Date of Issue :		07/07/2026
Registration no.:		DWTL/MKS/REG2627/00171		Condition of Sample :		Unsealed
Collection Point:		Treatment Plant (RO/CWPP/ARP/HH Purifier)		Quantity/Type of Bottle:		1000 ml / Plastic Bottles
Scheme/Source:		Not Mentioned(Not Mentioned)		Location/Depth :		jando ke muktsar / NA
Village :		Jando Ke		Habitation :		Jando Ke
Block:		Muktsar		District :		Muktsar
Latitude :		Not Mentioned		Longitude:		Not Mentioned
Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	pH	7.02@26°C	6.5-8.5	No Relaxatipn	--	IS 3025 (Part 11-2022) Electrometric Method
2	Colour	<5	5	15	CU	IS 3025(Part 4-2021) Visual Comparison Method
3	Odour	agreeable	Agreeable	Agreeable	--	IS 3025 (Part 5 – 2018) (Second Revision)
4	Taste	agreeable	Agreeable	Agreeable	--	IS 3025 (Part 8 – 2023)
5	TDS	100	500	2000	mg/l	IS 3025 (Part 16-2023) Gravimetric Method
6	Turbidity	0.5	1	5	NTU	IS 3025 (Part 10-2023) Nephelometric Method
7	T. Alkalinity(CaCO3)	60	200	600	mg/l	IS 3025 (Part 23-2023) Indicator Method
8	T. Hardness(CaCO3)	64	200	600	mg/l	IS 3025 (Part 21- 2009)(RA 2023) EDTA Method
9	Calcium(Ca)	16	75	200	mg/l	IS 3025 (Part 40-2024) EDTA Titrimetric Method
10	Magnesium(Mg)	6	30	100	mg/l	APHA (24th Ed.2023) Method: 3500-Mg+2 B By Calculation Method
11	Chloride(Cl)	40	250	1000	mg/l.	IS 3025 (Part 32-2025) Argentometric Method

This Report is issued under the following terms & Condition :

1. The results apply to the sample as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't beused be as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed, ND=Not Detected, T=Total)
5. * Value not available or test not performed for this parameter.
6. Temperature condition limit :25±5°C and Humidity condition limit:50 ±20%

Reviewed and Approved By

Ashish Kumar

Ashish Kumar
Sr. Chemist
Authorized Signatory
For, District Water Testing Laboratory
Sh. Muktsar Sahib

----- End of the Test Report -----